

## McCarthy Chevrolet Truck Shop

### Scope of Work For Myers Brothers

All Air Lines and Air Reels

9 - Electric Cord Reels 20 amp outlet - located in Reel Banks

1 - 10hp Duplex compressor 480 volt 3 phase  
requires separate feed to each motor

1 - Refrigerated Air Dryer by compressor, 120 volt 1 phase .59kw

All Lube Lines and Oil Equipment

Vehicle Lifts

6 - 12,000lb 2 post 208/230 volt 1 phase, 20 amp circuit

2 - 18,000lb 2 post 208/230 volt 1 phase, 20 amp circuit

1 - 50,000lb inground lift 10hp 480 volt 3 phase power unit

One 18' HVLS Fan - Centered in Shop 2.5amps 480 volt 3 phase

Vehicle Exhaust System - 2hp 480 v 3 phase Blower,  
2550 cfm @ 3" static pressure

All Detail Wash Curtains

### Required work by others for our equipment

4" Door Ports in (5) bay doors on South side of building

All Electrical - Including hook-up to our equipment

Exhaust System requires a manual starter w/ start stop switch  
which is NOT provide with our equipment.

We will need (2) 120v outlet for air dryer and tank alarm in oil room

We will need (3) NEMAL6-20P Plugs for Wheel Balancer,  
Tire Changer and Brake Lathe

We will need a 120volt outlet in front of alignment bay for console

Alignment rack requires 30 amp 208/230 volt 1ph power

Concrete Work -

Build pit for inground lift, concrete trough to controls

Finish concrete around inground lift after installation